

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CANNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/ 1173

Dated: 10/12/2024

FIRE SAFETY CERTIFICATE

Certified that the Zigysa Co-Ed. English Medium School at Kh. No. 76-81, Vill. Badusarai, New Delhi-110071, comprised of small basement (closed), ground plus two upper floors, owned/occupied by Zigysa Co-Ed. English Medium School was issued FSC by this department vide letter no. F.6/DFS/MS/School/2019/SZ/2301 dated 11/12/2019. The School building was re- inspected by the officer concerned of this department on 28.11.2024 in the presence of Sh. Kuldeep Gupta (Manager) and found that the School building have deemed complied the fire prevention and fire safety requirements in accordance with Rule-33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (ground plus two upper floors only) is fit for occupancy class "Educational" w.e.f 10/12/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 10/12/2024 at New Delhi.

(Arul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Manager, Zigysa Co-Ed. English Medium School at Kh. No. 76-81, Vill. Badusarai, New Delhi-110071.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 54.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

Principal
Zigysa

Co-ed English Medium School
Vill. Badusarai, Near Chhawla, New Delhi.

Manager
Zigysa

Co-ed English Medium School
Vill. Badusarai, Near Chhawla, New Delhi